NIT No.: IIITR/NIT/2022-23/01



भारतीय सूचना प्रौद्योगिकी संस्थान रायचूर

आई आई टी हैदराबाद कैंपस, कही, सम्मारेड्डी-502284 भारत. Indian Institute of Information Technology Raichur

IIT Hyderabad, Kandi campus, Sangareddy, Telangana - 502 284 India.

NOTICE INVITING TENDER (NIT)

Name of the work: SITC of 62.5kVA DG set along with AMF panel, DG Foundation, Earth pits and associated power supply works at IIIT Raichur GEC campus, Raichur.

Executive Engineer IIT Hyderabad (Mentor institute to IIIT Raichur)

Indian Institute of Information Technology Raichur

NOTICE INVITING TENDER

NIT Reference No.: IIITR/NIT/2022-23/01

Indian Institute of Technology Hyderabad (Mentor institute to IIIT Raichur) invites on behalf of President of India online Item rate bids (e-tender) / Percentage rate in Two Bid (Technical cum Eligibility + Financial) System, from approved and eligible Electrical contractors of CPWD and those of appropriate list of M.E.S. / BSNL/ Railways/ State P.W.D./Central PSUs/ State Govt. departments of Karnataka or working Electrical contractors of IIIT Raichur/ IIT Hyderabad for the following item as per the stipulated limits for below mentioned work.

The enlistment of the contractors should be valid on the last date of submission of bid.

Copy of valid contractor's registration certificate, PAN card, GST Registration certificate & GSTIN should accompany the Technical Bid.

1.1	NIT No.:	IIITR/NIT/2022-23/01
1.2	Name of Work:	SITC of 62.5kVA DG set along with AMF panel, DG Foundation, Earth pits and associated power supply works at IIIT Raichur GEC campus, Raichur.
1.2	Estimated Cost:	D- 40 5 (050 /
1.3	(given merely as a rough guide)	Rs. 10,76,079/-
1.4	Earnest Money Deposit (EMD):	Rs. 21,600/-
1.5	Period of Completion:	60 days
1.6	Date of Online Publication/Download of Tender	29/09/2022 1500hrs
1.7	Last Date for Submission of Bids	10/10/2022 1500hrs
1.8	Date and time of Opening of Technical Bids	10/10/2022 1530hrs
1.9	Date and time of Opening of Financial Bids	12/10/2022 1530hrs
1.10	Cost of Bid Document:	NIL

The Tender Document can be downloaded from https://mhrd.euniwizarde.com OR Central Public Procurement (CPP) Portal https://eprocure.gov.in/epublish/app OR Institute website-https://iiitr.ac.in/tenders.

The bid is to be submitted online mode only through the E-procurement portal of https://mhrd.euniwizarde.com up to the last date and time of submission of tender. Manual bids shall not be accepted. All quotation (both Technical and Financial) should be submitted online through E-procurement portal of https://mhrd.euniwizarde.com.

Any queries relating to the process of online bid submission or queries relating to e-tender Portal in general may be directed to the Helpdesk Support - Phone No. 011-49606060. Mail id: -helpdeskeuniwizarde@gmail.com.

INSTRUCTIONS FOR ONLINE BID SUBMISSION:

The Tender Document can be downloaded from https://mhrd.euniwizarde.com OR Central Public Procurement (CPP) Portal https://eprocure.gov.in/epublish/app OR Institute website-https://iith.ac.in/tenders.

The bidders are required to submit soft copies of their bids electronically on the https://mhrd.euniwizarde.com using valid Digital Signature Certificates. The instructions given below are meant to assist the bidders in registering on the Portal, prepare their bids in accordance with the requirements and submitting their bids online.

More information useful for submitting online bids may be obtained at: https://mhrd.euniwizarde.com

GUIDELINES FOR REGISTRATION:

- 1.Bidders are required to enrol on the e-Procurement Portal with clicking on the link "Bidder Enrolment" on the e-tender Portal by paying the Registration fee as applicable + Applicable GST.
- 2. As part of the enrolment process, the bidders will be required to choose a unique username and assign a password for their accounts.
- 3. Bidders are advised to register their valid email address and mobile numbers as part of the registration process. These would be used for any communication from the e-Wizard Portal.
- 4. Upon enrolment, the bidders will be required to register their valid Digital Signature Certificate (Only Class III Certificates with signing + encryption key usage) issued by any Certifying Authority recognized by CCA India (e.g. Sify / TCS / nCode / eMudhra etc.) with their profile or bidders can contact help desk for getting the DSC.
- 5. Only valid DSC should be registered by a bidder. Please note that the bidders are responsible to ensure that they do not lend their DSC's to others which may lead to misuse.
- 6. Bidder then logs in to the site through the secured log-in by entering their user ID/password and the password of the DSC / e-Token.
- 7. The scanned copies of all original documents should be uploaded in **pdf format** on portal https://mhrd.euniwizarde.com
- 8. After completion of registration payment, bidders need to send their acknowledgement copy on help

SEARCHING FOR TENDER DOCUMENTS:

- 1. There are various search options built in the e-tender Portal, to facilitate bidders to search active tenders by several parameters like Department name, Tender category, estimated value, Date, other keywords, etc. to search for a tender published on the Online Portal
- 2. Once the bidders have selected the tenders they are interested in, you can pay the form fee and processing fee (NOT REFUNDABLE) by net-banking / Debit / Credit card then you may download the required documents / tender schedules, Bid documents etc. Once you pay both fee tenders will be moved to the respective 'requested' Tab. This would enable the e- tender Portal to intimate the bidders through e-mail in case there is any corrigendum issued to the tender document.
- 3. The bidder should make a note of the unique Tender No assigned to each tender, in case they want to obtain any clarification/help from the Helpdesk.

PREPARATION OF BIDS:

- 1. Bidder should take into account any corrigendum published on the tender document before submitting their bids.
- 2. Please go through the tender advertisement and the tender document carefully to understand the documents required to be submitted as part of the bid.
- 3. Bidder, in advance, should get ready the bid documents to be submitted as indicated in the tender document / schedule and generally, they can be in **PDF/XLSX/PNG etc., formats**. Bid Original documents may be scanned with 100 dpi with Colour option which helps in reducing size of the scanned document.
- 4. To avoid the time and effort required in uploading the same set of standard documents which are required to be submitted as a part of every bid, a provision of uploading such standard documents (e.g. PAN card copy, GST, Annual reports, auditor certificates etc.) has been provided to the bidders. Bidders can use "My Documents" available to them to upload such documents.
- 5. These documents may be directly submitted from the "My Documents" area while submitting a bid, and need not be uploaded again and again. This will lead to a reduction in the time required for bid submission process.
- 6. Please note the number of covers in which the bid documents have to be submitted, the number of documents including the names and content of each of the document that needs to be submitted. Any deviations from these may lead to rejection of the bid.

SUBMISSION OF BIDS:

- 1. Bidder should log into the website well in advance for the submission of the bid so that it gets uploaded well in time i.e. on or before the bid submission time. Bidder will be responsible for any delay due to other issues.
- 2. The bidder has to digitally sign and upload the required bid documents one by one as indicated in the tender document as a token of acceptance of the terms and conditions laid down by IIT

Hyderabad (Mentor institute to IIIT Raichur)

- 3. Bidder has to select the payment option as "e-payment" to pay the tender fee / EMD as applicable and enter details of the instrument.
- 4. In case of Bank Guarantee (BG) bidder should prepare the BG as per the instructions specified in the tender document. The BG in original should be posted/couriered/given in person to the concerned official of IIT Hyderabad (Mentor institute to IIIT Raichur) before the Online Opening of Technical Bid. In case of non-receipt of BG in original by the said time, the uploaded bid will be summarily rejected.
- 5. Bidders are requested to note that they should necessarily submit their financial bids in the format provided and no other format is acceptable. If the price bid has been given as a standard BOQ format with the tender document, then the same is to be downloaded and to be filled by all the bidders. Bidders are required to download the BOQ file, open it and complete the white Colored (unprotected) cells with their respective financial quotes and other details (such as name of the bidder). No other cells should be changed. Once the details have been completed, the bidder should save it and submit it online, without changing the filename. If the BOQ file is found to be modified by the bidder, the bid will be rejected.
- 6. The server time (which is displayed on the bidders' dashboard) will be considered as the standard time for referencing the deadlines for submission of the bids by the bidders, opening of bids etc. The bidders should follow this time during bid submission.
- 7. All the documents being submitted by the bidders would be encrypted using PKI encryption techniques to ensure the secrecy of the data, which cannot be viewed by unauthorized persons until the time of bid opening.
- 8. The uploaded tender documents become readable only after the tender opening by the authorized bid openers.
- 9. Upon the successful and timely submission of bid click "Complete" (i.e. after Clicking "Submit" in the portal https://mhrd.euniwizarde.com), the portal will give a successful Tender submission acknowledgement & a bid summary will be displayed with the unique id and date & time of submission of the bid with all other relevant details.
- 10. The tender summary has to be printed and kept as an acknowledgement of the submission of the tender. This acknowledgement may be used as an entry pass for any bid opening meetings.
- 11. The off-line tender shall not be accepted and no request in this regard will be entertained whatsoever.
- 12. As per portal norms Tender Processing Fee will be applicable.

AMENDMENTS OF BID DOCUMENT:

At any time prior to the deadline for submission of Bids, the department reserve the right to add/modify/delete any portion of this document by the issuance of a Corrigendum, which would be published on the website and will also be made available to the all the Bidder who has been issued the tender document. The Corrigendum shall be binding on all bidders and will form part of the bid documents.

ASSISTANCE TO BIDDERS:

For any clarification in using https://mhrd.euniwizarde.com

- 1. Any queries relating to the tender document and the terms and conditions contained therein should be addressed to the Tender Inviting Authority for a tender or the relevant contact person indicated in the tender.
- 2. Any queries relating to the process of online bid submission or queries relating to e-Wizard Portal in general may be directed to the 24X7 e-Wizard Helpdesk Support.

Please feel free to contact euniwizard helpdesk (as given below) for any query related to e- tendering - Phone No. 011-49606060.

Mail id: - helpdeskeuniwizarde@gmail.com

The contact number for the helpdesk is 8448288994/86/87/89/88/81/90/92/82

011-49606060, 07903269552, 9355030608, 9055030613, 7903810198, 9355030606, 9315620706, 9355030623, 9355030628, 8800526452, 9205898228, 9122643040, 9355030604

eprochelpdesk.01@gmail.com, eprochelpdesk.44@gmail.com, eprochelpdesk.06@gmail.com

- 3. The tender inviting authority has the right to cancel this e-tender or extend the due date of receipt of the bid(s).
- 4. The bid should be submitted through e-Wizard portal (https://mhrd.euniwizarde.com/) only.

NOTICE INVITING TENDER

NIT Reference No.: IIITR/NIT/2022-23/01

Technical Criteria:

1. Bidders shall produce definite proof from the appropriate authority, which shall be to the satisfaction of the competent authority, of having satisfactorily completed/supplied similar material/works of magnitude specified below: -

Criteria of eligibility for submission of tender documents apart from basic eligibility:

Three similar works each of value not less than 40% of estimated cost or Two similar works each of value not less than 60% of estimated cost or One similar work of value not less than 80% of estimated cost in last 7 (Seven) years ending last day of the month previous to the one in which the tenders are invited.

The value of executed works shall be brought to current costing level by enhancing the actual value of work at simple rate of 7% per annum, calculated from the date of completion to the last date of submission of tender.

"Similar Work" shall mean "SITC (Supply, installation, Testing and commissioning) DG Sets OR Internal / External Electro-mechanical works Only such works will be considered, which are 100% completed in all respects on or before"

- **2.** To become eligible, the tenderer shall have to furnish an affidavit as per Form 'J' of the NIT.
- **3.** Agreement shall be drawn with the successful tenderer on prescribed Form which is available in the website: https://drive.google.com/file/d/19_LkFZ1leQb_3BznXQtinslcLISYVdbo/view (with up to date correction slips if any) Tenderer shall quote his rates as per various terms and conditions of the said form which will form part of the agreement.
- **4.** The time allowed for carrying out the work will be as stated at para 1 from the date of start as defined in schedule 'F' or from the first date of handing over of the site, whichever is later, in accordance with the phasing, if any, indicated in the tender documents.
- **5.** The site for the work is available.
- **6.** Tender documents consisting of plans, specifications, the schedule of quantities of the various classes of work to be done and the set of terms & conditions of contract to be complied with by the contractor whose tender may be accepted and other necessary documents can be seen for information at the above mentioned website.
- 7. Applicants are advised to keep visiting the above mentioned website from time to time (till the

deadline for bid submission) for any updates in respect of the tender documents, if any. Failure to do so shall not absolve the applicant of his liabilities to submit the applications complete in all respects including updates thereof, if any. An incomplete application may be liable for rejection.

- 8. The contractor whose tender is accepted, will be required to furnish performance guarantee of 3% (Three Percent) of the tendered amount within the period specified in Schedule F. This guarantee shall be in the form of Deposit at Call receipt of any scheduled bank/Banker's cheque of any scheduled bank/Demand Draft of any scheduled bank/Pay order of any scheduled bank or Fixed Deposit Receipts or Guarantee Bonds of any Scheduled Bank or the State Bank of India in accordance with the prescribed form. In case the contractor fails to deposit the said performance guarantee within the period as indicated in Schedule 'F'. including the extended period if any, the Earnest Money deposited by the contractor shall be forfeited automatically without any notice to the contractor.
- **9.** The description of the work is as follows:

"SITC of 62.5kVA DG set along with AMF panel, DG Foundation, Earthpits and associated power supply works at IIIT Raichur GEC campus, Raichur."

Tenderers are advised to inspect and examine the site and its surroundings and satisfy themselves before submitting their tenders as to the nature of the ground and sub-soil (so far as is practicable), the form and nature of the site, the means of access to the site, the accommodation they may require and in general shall themselves obtain all necessary information as to risks, contingencies and other circumstances which may influence or affect their tender. A tenderer shall be deemed to have full knowledge of the site whether he inspects it or not and no extra charge consequent on any misunderstanding or otherwise shall be allowed. The tenderer shall be responsible for arranging and maintaining at his own cost all materials, tools & plants, water, electricity access, facilities for workers and all other services required for executing the work unless otherwise specifically provided for in the contract documents. Submission of a tender by a tenderer implies that he has read this notice and all other contract documents and has made himself aware of the scope and specifications of the work to be done and of conditions and rates at which stores, tools and plant, etc. will be issued to him by the Government and local conditions and other factors having a bearing on the execution of the work.

- **10.** Tenders with any condition including that of conditional rebates shall be rejected forthwith.
- **11.** Cost of **Bid document cost** and **EMD** may also be remitted to Institute's account number as per bank particulars given below:

Name of the Account Holder : IITH-IIIT RAICHUR

Account Number : 38458293914 (Current Account)

Name of the Bank : State Bank of India

Address of the Bank : NH-65, IIT Hyderabad, Kandi Campus,

Kandi, Sangareddy, Telangana - 502284

Branch code : 14182

IFSC code : SBIN0014182 MICR code : 502002528 SHIFT code : SBININBB762

- **12.** The competent authority on behalf of the President of India does not bind itself to accept the lowest or any other tender and reserves to itself the authority to reject any or all the tenders received without the assignment of any reason. All tenders in which any of the prescribed condition is not fulfilled or any condition including that of conditional rebate is put forth by the tenderer shall be summarily rejected.
- **13.** Canvassing whether directly or indirectly, in connection with tenderers is strictly prohibited and the tenders submitted by the contractors who resort to canvassing will be liable to rejection.
- **14.** The competent authority on behalf of President of India reserves to himself the right of accepting the whole or any part of the tender and the tenderer shall be bound to perform the same at the rate quoted.
- **15.** The contractor shall not be permitted to tender for works if his near relative is posted a Divisional Accountant or as an officer in any capacity between the grades of Superintending Engineer and Junior Engineer (both inclusive). Any breach of this condition by the contractor would render him liable to be removed from the approved list of contractors of this Institute.
- **16.** No Engineer of gazette rank or other Gazetted Officer employed in Engineering or Administrative duties in an Engineering Department of the Government of India is allowed to work as a contractor for a period of one year after his retirement from Government service, without the previous permission of the Government of India in writing. This contract is liable to be cancelled if either the contractor or any of his employees is found any time to be such a person who had not obtained the permission of the Government of India as aforesaid before submission of the tender or engagement in the contractor's service.
- 17. The tender for the works shall remain open for acceptance for a period of Sixty (60) days from the date of opening of tenders/Sixty days from the date of opening of financial bid in case tenders are invited on 2/3 envelop system (strike out as the case may be) if any tenderer withdraws his tender before the said period or issue of letter of acceptance, whichever is earlier, or makes any modifications in the terms and conditions of the tender which are not acceptable to the department, then the Government shall, without prejudice to any other right or remedy, be at liberty to forfeit 50% of the said earnest money as aforesaid. Further the tenderer shall not be allowed to participate in the retendering process of the work.
- 18. (A) All taxes, Labor Cess etc., as applicable shall be borne by the contractor himself. The contractor shall quote his rates considering all such taxes including <u>GST on works</u>. Any recovery towards GST is notified by the competent authority, the same shall be effected and no claim what so ever shall be entertained by IITH. The contractor shall quote his rates accordingly.
 - (B) 2% as TDS amount of GST amount payable on the bills will be deducted as per the Govt. of India, Ministry of Finance, Department of Revenue notification vide No.65/39/2018-DOR, dtd: 14-09-2018.
- **19.** GST registration certificate of the state in which the work is to be taken up, if already obtained by the bidder.

If the bidder has not obtained GST registration in the state in which the work is to be taken up or as required by GST authorities, then in such a case the bidder shall scan and upload following under taking along with other bid documents.

"If the work awarded to me, I/We shall obtain GST registration certificate of the state, in which work is to be taken up, within one month from the date of receipt of award letter or before release of any payment by Indian Institute of Technology Hyderabad (Mentor institute to IIIT Raichur), whichever earlier, failing which I/We shall responsible for any delay in payments which will be due towards me/us on a/c of the work executed and/or for any action taken by IIT Hyderabad or GST department in this regard."

- **20.** Bidder has to submit Undertaking on their letter head pursuant to the Section 206AB (as applicable) of the Income Tax Act,1961 in prescribed format as enclosed at Annexure-A along with each and every bill submitted for payment.
- **21.** This notice inviting Tender shall form a part of the contract document. The successful tenderer/contractor, on acceptance of his tender by the Accepting Authority shall within 15 days from the stipulated date of start of the work, sign the contract consisting of:
 - a) The Notice Inviting Tender, all the documents including additional conditions, specifications and drawings, if any, forming the tender as issued at the time of invitation of tender and acceptance thereof together with any correspondence leading thereto.
 - b) Standard Contract form (General Conditions of Contract) as posted in the website of the Institute. The bidder is deemed to have gone through and understood the Standard Contract Form and the General Conditions of Contract.

Executive Engineer	
IIT Hyderabad	
(Mentor Institute to IIIT Raichur)	

(Signature of bidder)

AFFIDAVIT

I/we undertake and confirm that our firm/partnership firm has not been blacklisted by any state/Central Departments/PSUs/Autonomous bodies during the last 7 years of its operations. Further that, if such information comes to the notice of the department then I/we shall be debarred for bidding in IIT Hyderabad (Mentor institute to IIIT Raichur) in future forever. Also, if such information comes to the notice of Indian Institute of Technology Hyderabad (Mentor institute to IIIT Raichur) on any day before date of start of work, the Engineer-in-charge shall be free to cancel the agreement and to forfeit the entire amount of Earnest Money Deposit/Performance Guarantee (Scanned copy of this notarized affidavit to be uploaded at the time of submission of bid)

NOTE: Affidavit to be furnished on a 'Non-Judicial' stamp paper worth Rs.100/-

Signature of Bidder(s) or an authorized Officer of the firm with stamp

Signature of Notary with seal

Checklist of documents to be submitted along with Technical Bid

Sl. No.	Doc Ref	Description of the Document	Enclosed Yes/No	Remarks
	Applicant shall submit the following documents for Technical scrutiny			
1	As per NIT Registration of contractors.	CPWD and those of appropriate list of M.E.S. / BSNL/ Railways/ State P.W.D./Central PSUs/ State Govt. departments of Karnataka or working Electrical contractors of IIIT Raichur/ IIT Hyderabad		
2	PAN details	Copy of PAN card		
3	GST registration details	Copy of GST Registration certificate & GSTIN should accompany the Technical Bid		
	Details of similar woks	Not less than 40% of estimated cost (Three similar works)		
4	executed (Detailed statements to be enclosed)	Not less than 60% of estimated cost (Two similar works)		
	cheloseuj	Not less than 80% of estimated cost (One Similar work)		
5	As per Para No. 1.4 of NIT	Cost of EMD		
6	As per Sl.No.20 of NIT	Undertaking for GST registration in the state in which the work is to be taken up		
7	As per Sl.No.21 of NIT	Undertaking pursuant to Section 206AB (as applicable) of the Income Tax Act, 1961 (Proforma enclosed as Annexure-A)		

On Contractor/ Agency's Letter Head

<u>Undertaking pursuant to Section 206AB (as applicable) of the Income Tax Act, 1961</u>

To, Registrar IIT Hyderabad (Mentor institute to IIIT Raic Kandi, Sangareddy- 502284.	hur)	
Dear Sir/Madam,		
Subject: Declaration confirming filing of Incom	e Tax Return for immediate tv	vo preceding years.
I, Ms./Mrs./Mrin capacity andregistered office at has filed Income Tax R as mentioned below per due dates under Sectidetails of which are as given under:	do leturns for immediately last 2	hereby declare that preceding Financial Years
Financial Year for which Income Tax Return was due as per Section 139(1)	Acknowledgement no. of ITR filed under Section 139(1)	Date of Filing
2021-22		
(if applicable on date of this declaration) 2020-21		
2019-20		
Further, I confirm that hadate.	as lined the above PAN with A	adhaar number as on this
I also undertake thathereby (Mentor institute to IIIT Raichur) for any loss may arise due to incorrect reporting of above in For	s/liability (including any Tax, i	
Signature: Name of person: Designation: Place:		

PROFORMA OF SCHEDULES

SCHEDULE 'A'

Schedule of quantities (Enclosed): Part A (Item Rate)

SCHEDULE 'B'

Schedule of materials to be issued to the contractor

Sl. No.	Description of item	Quantity	Rates in figure & words at which the material will be charged to the Contractor	Place of issue
	NIL			

SCHEDULE 'C'

Tools and plants to be hired to the contractor

Sl.	No.	Description	Hire Charges per day	Place of issue
	NII.			

SCHEDULE 'D'

Extra schedule for specific requirements/documents for the work, if any.

--- NIL ---

SCHEDULE 'E'

Reference to General Condition of Contract.: Posted in the website of the Institute.

Name of the work : "SITC of 62.5kVA DG set along with AMF panel,

DG Foundation, Earth pits and associated power supply works at IIIT Raichur GEC

campus, Raichur."

Estimated cost of work : Rs. 10,76,079/-

Earnest money : **Rs. 21,600/-**

Performance Guarantee : 3.0% of the accepted tendered value

Security Deposit : 2.50% of the tendered value

SCHEDULE 'F'

GENERAL RULES AND DIRECTIONS:

Officer inviting tender: : Executive Engineer, IITH

Maximum percentage for quantity of items of work to

be executed beyond which rates are to be determined : See below

in accordance with Clauses 12.2 & 12.3

Definitions:

2(v) Engineer -in- Charge : Executive Engineer, Indian Institute of

Technology, Hyderabad.

2(viii) Accepting Authority : Executive Engineer, Indian Institute of

Technology, Hyderabad.

2(x) Percentage on cost materials and Labour to : 15% (Fifteen) per cent.

cover all overheads and profit

2(xi) Standard Schedule of Rate : CPWD, Delhi Schedule of Rates (DSR)

2022 Electrical, with up to date correction

slips.

Standard Contract Form : IITH General Conditions of Contract for

Maintenance works

Clause 1

i) Time allowed for submission of Performance : Guarantee, Programme Chart (Time and Progress) and applicable licenses, registration with EPFO, ESIC and BOCW Welfare Board or proof of applying from the date of issue of letter of thereof

acceptance, in days

15(Fifteen) Days

ii) Maximum allowable extension beyond the period

provided in (i) above 7 (Seven) Days

Clause 1A

Whether Clause 1A is applicable

Yes

Clause 2 : Executive Engineer, Indian Institute of

Authority for fixing Compensation under Clause 2 Technology, Hyderabad. **Clause 3(VII)**: If the contractor had secured the contract with Government as a result of wrong tendering or other non-bonafide methods of competitive tendering or commits breach of Integrity Agreement-will be made ineligible.

Clause 5:

Number of days from the date of issue of letter of acceptance for reckoning date of start

: 7 Days or date of issue of LOC

whichever is later

Milestones : As shown below

	Table of Milestones if Applicable			
Sl. No.	Description of Milestone	Time Allowed (From Date of Start)	Amount to be withheld in case of non- achievement of Milestone	
1	25% agreement value	One fourth of time allowed for completion.		
2	50 % agreement value	One half of time allowed for completion.	In the event of non-achieving the necessary progress as assessed from	
3	75% agreement value	Three fourth of time allowed for completion.	the running payments, 2.5% of tendered value of work will be withheld for failure of each milestone.	
4	100% agreement value	Full period of time allowed for completion.		

Time allowed for execution of work : 60 days

Authority to give fair and reasonable Extension : of time for completion of work (Web based hindrance register)

Rescheduling of mile stones

Clause 6:- Measurement Book

Executive Engineer, Indian Institute of Technology, Hyderabad.

Executive Engineer, Indian Institute of Technology, Hyderabad.

(i) For works having estimated cost more

than Rs 15 Lakh - Clause 6

(ii) For works having estimated cost Rs. 15 Lakh or less – Contractor's option of Clause 6 or to be exercised at the time of Tender Submission

Clause 7:

Clause applicable, 6

Gross work to be done together with net payment /adjustment of advances for material collected, if any, since the last such payment for being eligible to interim payment

Rs. 5 Lakhs/-

Clause 7A:

Whether Clause 7A is applicable

Yes.

No running account bill shall be paid for the work till the applicable labour licenses, registration with EPFO, ESIC and BOCW Welfare Board, whatever applicable are submitted by the contractor to the Engineer-

in-charge.

Clause 10A:

List of testing equipment to be provided by the :

contractor at site lab

As given in additional specifications

Clause 10B (i)- Secured advance on Materials:

Whether Clause 10 B (i) shall be applicable NA

Clause 10C:

Component of labour expressed as percent of value :

of work

NA

Clause 10CA Not Applicable

Sl No.	Material covered under this clause	Nearest Materials (other than cement, reinforcement bars and the structural steel) for which All India Wholesale Price Index to be followed	Base Price of all Materials covered under clause 10 CA* (INR)
	Reinforcement steel(TMT)		(90,000/-)/MT
	Cement		(8,600/-) /MT
	Structural steel		(1,01,000/-/MT

Clause 10CC Not Applicable

Clause 10D *Applicable*

Clause 11:

Specification to be followed for execution of : **For ELECTRICAL WORKS**

work

i) CPWD DSR Items:

CPWD General Specifications

Part I Internal 2013 Part II External 1994

Part III Lifts & Escalators 2003

Part IV Substations 2013

Part V Wet Riser Sprinkler System 2006

Part VI Heating, Ventilation & Air

Conditioning Works 2017 Part VII DG Sets 2013

Part VIII: Gas based fire extinguisher systems 2013 all with up to date Corrections Slips.

For all Market Rate Items:

Particular Specifications

Clause 12:

12.2 & 12.3: Deviation limit beyond which

Clause 12.2 &12.3 shall apply for building work : 100% (as per CPWD circular No. DG/CON/313

Dt: 17.02.2021

12.5 : Deviation Limit beyond which clauses

12.2 & 12.3 shall apply for foundation work : 100% (One hundred per cent)

Clause 14:

Whether Clause 14 is applicable : Yes.

Clause 16 : Superintending Engineer, IIT Hyderabad

Competent Authority for deciding reduced rates.

Clause 18: : As required for the work.

List of mandatory machinery, tools & plants to

be deployed by the contractor at site

Clause 25:

(i) Constitution of Dispute Redressal
Committee (DRC) (DRC shall constitute one
Chairman and true members)
: Director, IIIT Raichur

Chairman and two members)
Competent Authority to appoint
DRC

(ii) Place of arbitration : Raichur, Karnataka State

Clause 32: As required for the work.

Clause 38

(i): Schedule/statement for determining theoretical quantity of cement & bitumen on the basis of Delhi Schedule of Rates

DSR - 2022 Electrical published by CPWD

(ii): Variations permissible on theoretical quantities:

(a) Cement 2% plus/minus

(b) Bitumen All Works 2.5% plus only & nil on minus side.

(c) Steel Reinforcement and structural steel sections for each diameter, section and 2% plus/minus category

Special Conditions of Contract

SPECIAL CONDITIONS

- 1. Before tendering, the Agency shall inspect the site of work and shall fully ac-quaint himself about the conditions prevailing at site, availability of materials, avail- ability of land and suitable location for construction of godowns, stores and camp, transport facilities, the extent of lead and lifts involved in the work (over the entire duration of contract) including local conditions, as required for satisfactory execution of the work and nothing extra whatsoever shall be paid on this account.
- 2. The Agency shall at his own expense and risk arrange land for accommodation of labour, setting up of office, the storage of materials, erection of temporary work- shops, and construction of approach roads to the site of the work including land required for carrying out of all jobs connected with the completion of the work. In any case. IIT Hyderabad (Mentor institute to IIIT Raichur) (Institute) shall not permit setting up of labour camps within its premises. If during construction it becomes necessary to remove or shift the stored materials shed workshop, access roads, etc. to facilitate execution of any other work by any other agency, the contractor shall do as directed by the Engineer-in-charge and no claim whatsoever, shall be entertained on this account.
- 3. It shall be deemed that the contractor shall have satisfied himself as to the nature and location of the work, transport facilities, availability of land for setting up of camp etc. The department will bear no responsibility for lack of such knowledge and the consequences thereof.
- 4. The Agency shall have to make approaches to the site, if so required and keep them in good condition for transportation of labour and materials as well as inspection of works by the Engineer-in-charge. Nothing extra shall be paid on this account.
- 5. The Agency shall at his own cost submit samples of all materials sufficiently in advance and obtain approval of the Engineer-in-charge. Subsequently, the materials to be used in the actual execution of the work shall strictly conform to the quality of samples approved by the Engineer- in-charge and nothing extra shall be paid on this account. The acceptance of any sample or material on inspection shall not be a bar to its subsequent rejection, if found defective.
- 6. The contractor shall at his cost, make all arrangements and shall provide necessary facilities as the Engineer-in-charge may require for collecting, preparing, packing forwarding and transportation of the required number of samples for tests for analysis at such time and to such places as directed by the Engineer-in-charge, and bear all charges and cost of testing unless specifically provided for otherwise elsewhere in the contract or specifications. The cost of tests shall be borne by the contractor/Institute in the manner indicated below (except for water):
 - a) By the contractor, if the results show that the material does not conform to relevant specifications and BIS codes or any other relevant code for which conformity test is carried out.
 - b) By the Institute, if the results show that the material conforms to relevant specifications and BIS codes or any other relevant code for which conformity test is carried out.
- 7. Materials used on work without prior inspection and testing (where testing is necessary) and without approval of Engineer-in-charge are liable to be considered unauthorized, defective and not acceptable. The Engineer-in-charge shall have full powers to require removal of any or all of the materials brought to site by contractor which are not in accordance with the contract, Specifications

or do not conform in character or quality to the samples approved by the Engineer-in-charge. In case of default on the part of the contractor in removing rejected materials, the Engineer-in- charge shall be at liberty to have them removed at the risk and cost of the contractor.

- 8. The work shall be carried out in such a manner so as not to interfere/or effect or disturb other works being executed by other agencies, if any.
- 9. Any damages done by the contractor to any existing work or work being executed by other agencies shall be made good by him at his own cost.
- 10. The work shall be carried out in the manner complying in all respects with the requirement of relevant rules and regulations of the local bodies under the jurisdiction of which the work is to be executed and nothing extra shall be paid on this account.
- 11. The contractor shall maintain in good condition all work executed till the completion of the entire work entrusted to the contractor under this contract and nothing extra shall be paid on this account.
- 12. No payment will be made to the contractor for damage caused by rain, floods and other natural calamities whatsoever during the execution of the works and any damage to the work on this account shall have to be made good by the contractor at his own cost and nothing whatsoever' shall be paid on this account.
- 13. The Item Rates or Percentage Rates for all items of work, unless clearly specified otherwise shall include the cost of all labour for materials, de-watering and other inputs involved in the execution of the items.
- 14. No claim whatsoever for idle labour, additional establishments, costs of hire and labour charges for tools and plants etc. would be entertained under any circumstances.
- 15. For the safety of all labour directly or indirectly employed in the work for the performance of the contractor's part of this agreement, the contractors shall, in addition to the provisions of Safety code and directions of the Engineer-in-charge make all arrangements to provide facility as per the provisions of Indian Standard Specifications (Codes) listed below and nothing extra shall be paid on this account.
- (a) IS 3696 Part I Safety Code for scaffolds and ladders
- (b) IS 3696 Part II Safety Code for scaffolds and ladders Part II ladders
- (c) IS 764 Safety Code for excavation work
- (d) IS 4081 Safety Code for Blasting and Drilling operations,
- (e) IS4138 Safety Code for working in compressed air.
- (f) IS 7293 Safety Code for working with construction machinery
- (g) IS 7969 Safety Code for storage and handling of building materials
- (h) IS 5216:1982 code of safety procedures and practices in electrical works
- 16. The contractor shall take all precautions to avoid all accidents by exhibiting necessary caution boards and by providing red flags, red lights and barriers. The con-tractor shall be responsible for any accident at the site of work and consequences thereof.

- 17. Labour Welfare Cess @ 1% shall be deducted at source from the bills of Gross value (which includes the cost of stipulated materials) of the work done and Government shall not entertain any claim whatsoever in this respect in this contract.
- 18. The ESI and EPF Contribution on the part of the employer in respect of the contract shall be paid by the contractor. This contribution on the part of the employer paid by the contractor shall be reimbursed by the Engineer-in- Charge to the contractor on actual basis. The applicable and eligible amount of EPF and ESI shall be reimbursed preferably within 7 days but not later than 30 days of submission of documentary proof of payment provided same are in order.
- 19. No Running Account Bill shall be paid for the work till the applicable labour license, registration with EPFO, ESIC and BOCW Welfare Board, whatever applicable are submitted by the contractor to the Engineer-in-charge.
- 20. The contractor shall obtain a valid licence under the contract labour (R A) Act, 1970 and the contract labour (Regulation and Abolition) Central Rules, 1971 before the commencement of the work, and continue to have a valid licence until the completion of the work. The contractor shall also comply with provision of the Inter- State Migrant Women (Regulation of Employment and conditions of service) Act 1979.
- 21. All tools, tackles, safety equipment and labours required for maintenance and testing works / AMC at all levels and heights shall have to be provided by the tenderer at no extra cost.
- 22. Spare parts used by vendor should conform to IS specifications as applicable.
- 23. Any damaged due to mishandling by the person deputed by the vendor shall have to be restored back to its original condition by the vendor at their own cost.
- 24. The contractor shall rectify defects developed in the Systems within DLP period promptly. In case the contractor does not rectify the defects, IITH may restore the System in working condition on contractor's expenses. penalty will be @ 1% of the cost of the system per week or part thereof for the first instance subject to a maximum limit of 10% of the same value.

Brief description and detailed scope of work is enclosed at Annexure - B

TECHNICAL SPECIFICATION

SECTION-I SPECIFICATIONS (GENERAL)

1.0 **SCOPE**

- A) The specification covers the general requirement for manufacturing, inspection, testing & supply, installation, testing & commissioning of 62.5 KVA SILENT Diesel Engine driven alternator suitable for operation with Auto Mains Failure system along with AMF panel, cabling, panels, cabling etc as per the site. Loading, unloading, transportation of new D.G., new AMF Panel are in the scope of Supplier/Contractor including requisite Civil works.
- B) The alternator is driven by I. C. Diesel Engine as per following technical specifications. Specification for the Alternator Section II

Specification for Engine - Section III

Specification for soundproof enclosure - Section IV

Specification for AMF Panel (inclusive of - Section V Control & Monitoring Panel)

- C) Vendor to obtain statutory permissions like CEA, PCB/ CPCB as per the requirement. The offered DG set must have type approval meeting CPCB-2 norms for smoke emission and also noise emission.
- 1.1 Documents to be submitted with Technical Bid:
- a) Alternator
- b) Engine
- c) AMF Panel
- d) Documentation

1.2 Installation location

The DG set shall be installed outdoor in acoustic enclosure (specification for which has been provided in the document) at IIIT Raichur, GEC Campus.

1.3 *General*

- 1.3.1 All the supply & work shall be in accordance with the relevant IS Specifications, recognized standards, modern approved practice and shall meet the requirements of the latest issue of applicable codes, factory rules and regulations, supply codes.
- 1.3.2 All the materials & accessories provided by Contractor under terms of this contract shall confirm to relevant IS Specifications samples of all equipment's, materials, and accessories to be supplied by Contractor shall be submitted for the approval of Engineer before the use.
- 1.3.3 Contractor shall provide all necessary labor, tools, scaffolding and requisite work like drilling, cutting, welding at his cost.
- 1.3.4 Good workmanship is the essence of this contract and shall be complied with at all times. The Contractor shall have the works supervised by qualified & experienced Engineer. All the defects pointed out by the Engineer shall be rectified immediately by the contractor free of cost.
- 1.3.5 Applicable Indian Electricity Rules, Act (latest), CPCB Norms and all other statutory regulations that might be relevant to the installation shall be followed.
- 1.3.6 No alteration which may affect the structures and architecture of building shall be done without the prior approval of the engineer. All work shall be carried out in such a manner that it should not cause

any inconvenience to other works which are under progress. The Contractor shall cooperate with other agencies in the area for the smooth execution of all works.

1.3.7 Accidental damage to any property shall be reported immediately to site engineers and letter confirmed in writing.

1.3.8 Operation and Maintenance spares: -

Bidder shall provide the list of spares required as standby to maintain the DG Set in Good working condition.

1.4 <u>Tests and Inspection</u>:

The authorized representatives from IIT Hyderabad may visit the works during manufacture of equipment to assess the progress of work as well as to ascertain that only quality raw materials are used for the same. They shall be given all assistance to carry out the inspection without any extra cost.

To conduct factory and site load test as per requirement as stated in the Tender specification including sufficient sized load bank in order to conduct full load testing as required. For factory test, the cost of travelling to the factory, lodging & boarding expenditure of 2 persons to be included in the rate quoted.

For Diesel Engine:

Manufacturer's internal test certificates in line with IS-10002 /BS-5514 shall be furnished for review and vetting by the engineer/engineers during inspection of combined assembly DG set.

For Alternator:

Manufacturer's internal test certificates in line with IS-4722 - 1968 shall be furnished for review and vetting by the engineer/engineers during inspection of combined assembly DG set.

- 1.5 All major items/equipment's i.e. engine & alternator in assembled condition, associated AMF panel etc. shall be offered for inspection & testing at factory/ manufacturers work.
 - a) Complete set along with AMF panel shall be tested for control wiring, manual, automatic start, stop function including fault tripping/ protection of the set. AMF panel shall be tested separately for all routine & functional test prior to load test.
 - b) Dimensions and Alignment.
 - c) DG Set control panel, safety / protective devices, interlocks, IR, HV, Phase sequence, voltage regulation, frequency.
 - d) The DG set shall be tested on NO Load for 30 mins, at 25% of load for 30 mins, 50% and 75 % for one hour each and fuel consumption will be record.
 - e) Full Load testing of complete set at 100% rated load with acoustic enclosure till the differential temperature remain steady but not less than 3 hrs. The engine and alternator parameter shall not exceed the guaranteed value during the testing. Fuel consumption shall be recorded.
 - f) Overload testing at 110% load for one hour immediately after the full load test.
 - g) Smoke test certificate as per rules.
 - h) The noise level at 1 m from the enclosure and the temperature rise inside the enclosure shall be measured during the load test.
 - DG Vendor to Study Site & Confirm Transportation of DG set to location without Dismantling any component after Factory Test is Conducted. **Vendor to make all constructional damages good to any part of the building during transportation, unloading.**

1.6 Site Testing:

Following tests shall be conducted at site in the presence of the Engineer during commissioning. The contractor shall provide all testing equipment, labour and consumables required for the testing (Diesel oil shall be arranged by the contractor only) with DG set load testing as stipulated in specifications/BOQ. Entire cost is to be borne by Vendors.

- a) Checking the alignment by engine manufacturer's representative and obtaining approval.
- b) Checking the AMF operation both on auto and manual mode, start, stop, tripping / protection, functional and routine tests.
- checking the DG Set safeties and interlocks for satisfactory operation.
- d Checking vibration levels.
- e) Testing of individual protective devices on engine and alternator & ensuring that the wiring is carried out properly.
- The DG set shall be tested for different loads at site with suitable load bank. Load bank with all necessary accessories shall be arranged by the contractor. All the readings shall be logged to evaluate the fuel consumption, tube oil pressure, water and oil temperature vis-à-vis the electrical load.

Any deviation from the guaranteed parameters shall be made good and these performance parameters should be measured once again till the required results are achieved.

The DG set shall be deemed to be commissioned after satisfactory performance of all associated equipment's.

1.6 Compliance:

- a) The DG set being provided by the bidder shall comply with latest environment protection rules and latest BIS standards. Conformance label as per the said rule is to be affixed on the DG set. A copy of each type approval certificate and conformity of production certificate is to be provided in along with the offer. Supplier shall clearly specify the codes and standards for designing manufacturing, inspection and testing of the DG Set along with the bid.
- b) All the cables route to be marked at both sides of cable termination and letter to be imposed.
- c) Other staff training shall include training sessions provided on site after hand over of the system. The training sessions shall be given by an experienced and competent engineer familiar with system installed. The scope of training provided shall include full operating instructions in the use of DG Set.
- d) The contractor shall provide operating instruction as required for operating the system. "Hands-on" demonstrations of the operation of all system components and the entire system including program changes and functions shall be provided.
- e) The contractor and/or the systems manufacturer's representatives shall provide printed Sequence of Operation sheets for ready reference.

SECTION -II ALTERNATOR SPECIFICATION

1.0. Rating & General

The DG Set shall be Prime Power rating Duty as per ISO: 8528-1. It comprises of alternator which shall be self-excited, self-regulated and shall be rated for an output of 62.5 KVA Continuous Duty Power at 415 Volts, 3 Phase, 50 Hz suitable for the 4 wire system exclusive of power requirement of auxiliaries. Winding is to be STAR connected and neutral shall be brought out through a separate terminal and will be solidly grounded.

Rating Voltage : 62.5 KVA (Continuous Duty)

: 415 Volt 3 Phase with neutral brought

out through separate terminal

Frequency : 50 Hz Degree of Protection : IP23

RPM : 1500 RPM Duty Rating : Continuous

S1 Short circuit withstand

Capacity : 3 times FLC for 10seconds

Overload : 110% load for one hour in 7 hours

Suitability for parallel :

Operation Harmonic

Distribution factor : NL L-L

2.5% Unbalanced Load : 25% Ball Bearing : SINGLE

1.1 Excitation

Self-excited, self-regulated and with **brushless type** solid state excitation facility. The rectifier shall be suitable for operation at high ambient temperature at site as indicated in Specification. Over excitation protection shall be provided as per Alternator Manufacturer standard.

2.0 Standards

The alternator shall be in accordance with latest editions of the following standards:

- i) IS: 4722/68 & BS: 2613/1970. The electrical performance of rotating electrical machine.
- ii) IS: 4889/68 & BS: 269/1970, Rules for method of declaring efficiency of electrical machine.
- iii) Other IS/BS/IEC/EN applicable for design, manufacturing, testing and supply of subject Alternator/DG set like IEC 43, BS 6250, EN62581, IS13364 (I&II) with CE marking.

3.0 **Voltage Regulation**:

An automatic voltage regulator system compatible with excitation system described above shall be provided, so as to furnish a performance as defined herein under all conditions of loads. The AVR shall be static type with provision for control from remote through push buttons.

4.0 <u>Performances</u>:

Voltage regulation from no load to rated load shall be within a range of 2.5% for rated voltage. The frequency regulation from no load to full load shall be as defined by the Engine Governor. Voltage dip for any addition of load up to and including 60% load shall not exceed 15% of rated voltage and shall recover to and remain within the steady band within not more than 1.5 sec. Similarly,

the frequency shall recover to the steady state frequency band within 5 seconds. The windings shall not develop hot spots exceeding safe limits due to an imbalance of 25% between any two phases from no load to full load.

5.0 *Enclosure*

Alternator enclosure should be screen protected drip proof (IP23) conforming to IS: 4691 – 1968.

6.0 Terminal Box

It shall be suitable for necessary PVC insulated 1.1 KV grade 2 Nos. of 3.5Core 95 / 120 sq mm Al. armoured cable conforming to IS: 1554 – Part – I with sufficient space for bifurcation inside the box. Necessary individually removable gland plates, cable lugs, connections shall all be included. Suitable segregation shall be available for other cables such as excitation, control etc. The terminal box shall be suitable for withstanding the mechanical and thermal stresses developed due to any short circuit at the terminals.

Two Nos. earth terminals on opposite side with vibration proof connections, nonferrous hardware etc. With galvanized or plated and passivated washers of minimum size 12 mm dia. shall be provided.

7.0 Windings: Class H insulation shall be used.

8.0 Space Heaters

Space heater to be incorporated in the alternator to maintain the winding temperature such that it does not absorb moisture during long idle periods. The heater terminals shall be brought to a separate terminal box suitable for $240\,\mathrm{V}$ 50 Hz AC supply.

9.0 Under Speed Protection:

Alternator shall be provided with under speed protection.

10.0 Parallel Operation:

Parallel operation provision shall be provided as in-built part of AVR.

11.0 Wave Form:

Sinusoidal Wave form with THD content line to line on no load shall be less than 5%.

12.0 Transient Voltage Dip:

Transient voltage Dip due to sudden application of full load shall be taken care.

13.0 Radio interference shall meet VDE 0875(N).

14.0 Painting, Packing and Transport

All metal surfaces shall be thoroughly cleaned of scale, rust, and grease etc. prior to painting. Cleaned surface shall be given two coats of primer and prepared for final painting. Final finish shall be free from all sorts of blemishes.

The equipment shall be shipped to site suitable packed to prevent and damage. Each package shall have labels to show purchaser's name, purchase order and equipment no. Suitable lifting lugs etc. shall be provided and lifting points shall be clearly marked on the package. Packing shall be suitable for storage at site for a minimum period of 8 months.

SECTION - III ENGINE SPECIFICATION

1.0 SPECIFICATIONS FOR DIESEL ENGINE

1.1 Engine

The major subassemblies of the prime mover shall be as follows:

- i) Four stroke diesel oil engine, Battery starting type, Turbocharged, coolant cooled/Water cooled, Forced feed lubricated with its auxiliaries.
- ii) Steel channel fabricated common base plate (skid) for engine and alternator along with antivibration mounting pads.
- iii) Flex Plate cum Fly Wheel Bolted type coupling method between Engine and Single Bearing type Alternator.
- iv) Control system for the Diesel engine.

1.2. The engine shall be rated suitably to meet the requirement of alternator at its maximum rating and overload of 10% of the rated output for 1 hour in 07 hours of running as per Prime Power Duty definition mentioned in ISO:8528-I.

- 13 The diesel engine offered shall be suitable for operation with high speed diesel oil as per IS: 1460 Grade A. Performance requirement of the engine shall meet the requirement of IS-10002/BS-5514 standards (latest editions).
- 14 The diesel engine shall be furnished with all accessories like governor, daily service fuel tank, exhaust piping with exhaust silencer (Residential type silencer) and spark arrestor etc. The fuel tank shall be 12 Hrs diesel consumption on full load capacity and shall be fitted within Acoustic Enclosure with visual fuel level indicator/ Gauge, fuel level switches with fuel filling provision with steel channel structure to mount the tank and inter-connecting fuel piping,
- **1.5** The engine set shall have proper instrumentation & control for semi automatic operation as per the following:

1.5.1 Unit Start-Up

The DG set shall be started by means of battery. The unit shall be controlled locally for inspection, periodic start-up, check and normal operation. It shall have the facility to remotely switch on/off through auxiliary potential free contacts of relay to be provided in the AMF Panel. The engine control circuit shall provide terminal contacts for permissive signal to run/ stop from an external relay contact that will close by shorting the terminals and allow the engine to start/ stop on remote mode from Owner's control panel.

1.5.2 Unit Shut Down

The shutdown of DG shall be made effective through a STOP solenoid switch mounted on the acoustic enclosure. The DG set shall permit:

- a) Immediate automatic shut-down of the unit due to irregular operation and shall have provision for creating audio-visual signals of shut- down cause at the AMF panel which shall include the following:
- i) Low lube oil pressure (through a pressure switch).
- ii) High Jacket water temperature (through a temperature switch)
- iii) Diesel tank fuel level low (through a level switch).
- iv) Engine fails to start.
- v) Engine over speed.
- vi) Engine Overload
- b) To facilitate generation of these fault signals suitable instruments/relays having required

potential free contacts shall be provided for effecting the above. All these potential free contacts shall be wired to terminate in a separate terminal strip with proper identification in the engine local control panel. Status of potential free contact shall be changed as soon as above mentioned parameters reaches/ crosses their acceptable limits. Initially during the starting lube oil pressure switch shall be bypassed and will regain its normal status after start. Necessary provision shall be made for remote starting/stopping of the engine through push buttons mounted in the AMF panel. All the above-referred contacts shall be wired up to a terminal strip for wiring up to remote AMF panel.

16 Operation

Suitable facilities shall be provided for operation and monitoring of the Engine which shall include the following: -

For status monitoring (local), following gauges shall be available in engine local control panel.

- i) Engine Lube oil pressure gauge
- ii) Engine Jacket water.
- iii) Ammeter for battery charging.
- iv) DG set in Local / Remote / Manual indication.
- v) Digital hour-cum-RPM indicator.

1.7 Lubricating oil system

- 1.7.1 The engine shall be complete with its own self-contained lubricating oil system in which all the moving parts shall be lubricated by force feed system with the pump driven by the power drawn from the engine.
- 1.7.2 Heat exchanger type in-built lube oil cooler shall be provided for cooling the lube oil.
- 1.7.3 Full flow paper / felt element lube oil filters (simplex / duplex) shall be provided at the beginning of lubricating oil circuit. Filter shall be equipped with a by-pass arrangement to make it possible to change the filter (while the engine is running) by using by-pas filter.
- 1.7.4 As per the manufacturer's standard design, lube oil pump shall be provided for providing lubrication when the engine is not running.

18 Starting system

The engine shall be started from cold by automotive type lead acid battery both locally or from remote.

1.8.1 Electrical system

Engine electrical system shall consist of the following:

- i) **Battery**: Automotive low maintenance type lead acid battery of reputed brand and having sufficient capacity & terminal voltage for continuous duty application shall be supplied. Battery capacity & the connecting cables sizes shall be adequate so as to avoid problem of poor starting of the engine. The battery capacity shall not be less than 12Volt 95AH. Supplier shall furnish details of Battery capacity calculations along with the bid.
- ii) **Dynamo**: A dynamo shall be provided with the engine. This Dynamo shall be generating a charging current whenever the engine is operating. This shall be sufficient to continuously charge the battery.
- ii) For facilitating battery trickle /boost charging during idling of engine, the battery shall have a static battery charger to be installed in the AMF panel.
- iv) **Starter Motor**: The cranking of the engine shall be through a starter motor. The starter motor shall be provided with sealed type bearing.

v) All the interconnecting cables (Except main Power cable) with require no. of core for interconnecting fuel tank level switches, DG starting battery to Engine and to AMF panel, all the engine control/protection parameter from engine to AMF panel including interconnection of AMF panel to Owner's MCC panel where DG incomer & Main incomer are located shall be in the Vendor scope of supply. Supplier shall furnish details of electrical parts & its make for which the make/details are not mentioned in the tender.

1.9 Exhaust System

- 1.9.1 Exhaust piping shall be provided by the Vendor as per the Pollution Control Board's guidelines of the Telangana state.
- 1.9.2 Exhaust piping system should be adequately insulated and protected by a robust Aluminum cladding cover over glass wool and a shield to prevent fuel spray on to the cladding cover, in case of failure of fuel injector piping. The exhaust piping system shall be complete in all terms to provide the exhaust piping from engine to outside atmosphere within battery limit.
- 1.9.3 Exhaust silencers (residential type) with spark arrestor shall be supplied with the engine. The silencer shall be provided with 50 mm thick glass wool insulation and with 26 SWG Aluminium cladding.
- 1.9.4 The silencer shall be finished with rust preventive primer. Flexible sections shall be connected between the exhaust pipe and the engine exhaust manifold. The flexible exhaust pipe shall be of carbon or stainless steel, smoke tight and inner diameter same as of exhaust pipe. The exhaust piping shall be extended as per IS standards.
- 1.9.5 All the additional pipe, bellow, vertical length, right angle band, horizontal length including cladding of pipe with all required glass wool cladded with Aluminium foil/sheet as deemed fit, shall be supplied by the Vendor. The DG Set shall be kept in open. Details of lengths for each part of the exhaust system shall be indicated.

1.10 Fuel Oil System

- 1.10.1 The fuel oil circuit shall include: -
- i) Independent daily service tank of 850 ltrs. capacity or continuous operation of 12 hours shall be provided. The fuel tank shall have provision for flanged inlet/outlet connections, vent, top cover with opening, overflow drain, drain plug, breather and also necessary level monitoring instrumentation and alarm. Fuel tank shall be installed/housed within Acoustic Enclosure.
- ii) The bidder shall supply Manual type fuel transfer pump for filling of fuel tank like in automobiles as per site condition.
- iii) Pipe, flanges, fittings, valves, gaskets and all other material required for the circuit i.e. from fuel tank to Engine.
- iv) Full flow fuel filters, fuel inlet & outlet, air vent, drain plug etc. Level indicator inside the fuel tank and level switch (High & low) indication on Control Panel with alarm to be provided.
- v) Fuel tank shall be fabricated from 2 mm thick CRCA sheet.
- vi) The fuel level shall be measured through a dip stick / Gauge / Electronic fuel indicator with high and low level indications.
- vii) Fuel tank shall be provided with strainer.
- viii) Fuel tank connected to engine with wire breaded fuel pipes.
- ix) The fuel tank shall be painted after Antirust treatment as mention in Sound Proof Enclosure specifications.
- x) The fuel tank preferably shall be located at Subbase/ within Acoustic Enclosure as per approved design by DG Set OEM/ Manufacturer.

1.11 Cooling System

- 1.11.1 The engine waste heat shall be dissipated to a closed circuit water system which in turn shall be cooled by radiator cooling system driven by the power from the engine. The proposal shall be complete including the necessary pipe work for radiator, accessories etc. for the cooling system.
- 1.11.2 Engine jacket water shall be circulated by an engine driven self priming pump.
- 1.11.3 Jacket water valve / Thermostatic switches for temperature control and alarm will be provided as per design.

1.12 Engine Governor

1.12.1 An over speed device required to shut off the system.

1.12.2 Fly Wheel

Engine shall be fitted with a heavy flywheel with guard to ensure smooth operation throughout the speed range and at rated power. The effect of this fly wheel shall be such that cyclic irregularity of the system should comply with (or better than) the limit laid down in BS-5514.

1.13 Name Plate

A corrosion resistant name plate of proper size shall be securely fastened by stainless steel pins at an easily visible and accessible point on the engine and gear unit. The name plate shall be stamped with the following information.

- i) Type, Model and Serial Number
- ii) Brake Horse Power
- iii) RPM
- iv) Manufacturer's Name
- v) Conform to which standard.
- vi) Weight
- vii) Firing order of the engine.

In addition to the above an arrow shall be stamped at an easily observable point on the engine to indicate direction of rotation.

SECTION - IV SOUND PROOF ENCLOSURE

1.0 CONSTRUCTION

- a) The Enclosure should be designed for easy access to serviceable parts.
- b) Modular construction for easy assembling and dismantling.
- c) Fabricated out of CRCA sheet of 1.6 mm. Base Frame shall be made out of ISMC of suitable sections or made out of sheet steel minimum of thickness 5 mm.
- d) The hardware shall be of high tensile grade i.e. bolts of 10.9/8.8 grade. Hardware should be passivized.
- e) Battery should be accommodated in a separate tray in the enclosure.
- f) There should be provision for drain plugs for draining mobile oil.
- g) The doors should be gasket with high quality EPDN gaskets to avoid leakage sound.
- h) The door handles should be lockable type.
- 1.1 **PAINTING** (for Fuel tank, Soundproof Enclosure, AMF Panel, Control Panel etc.)
- a) The sheet metal components should be hot dip seven tank pre-treated.
- b) Proper Antirust treatment shall be provided to suit the location
- c) To have long life of container it should be P.P. based powder coated (inside as well as outside).
- d) Base frame should be epoxy quoted when fabricated.

1.2 ACOUSTIC ENCLOSURE

- a) Sound proofing of enclosure should be done with quality rock wool/mineral wool confirming to IS-8183 of 64 Kg/M3density.
- b) The rock wool /Glass wool should further be covered with fibre glass cloth/fiber tissue paper fire resistive and perforated powder coated sheet of 0.6 mm thickness.
- c) Residential silencer shall be provided within the DG to control the exhaust noise.
- d) Interconnection between silencer and engine should be through stainless steel flexible hose/pipe.
- e) Attenuators should be provided to control sound at air entry to the container and exit from the container.

1.3 VENTILATION AND AIR CIRCULATION

The system shall be engineered to provide air inlet/exhaust acoustic louvers for efficient air circulation and shall have following special features:

- a) Adequate ventilation is to be provided to meet air requirement for combustion and heat removal.
- b) The temperature inside the enclosure shall not exceed 40 degree centigrade above ambient under full load condition while ambient is below 35 Deg. C. There should be no derating due to temperature under Full load condition (100% load).

1.4 ELECTRICAL

- a) The earthing point shall be isolated through DMC insulator mounted on enclosure.
- b) Control panel should be mounted in the container itself. All parameters should be visible from outside and all push buttons accessible easily.

1.5 GENERAL

- a) Engine carries warranty/guarantee of engine manufacturer for the DG Set in the enclosure of Silent Diesel Generating Set.
- b) Emergency Stop Push Button shall be provided outside the container. The maximum sound pressure level shall be average 75 db(A) at one meter from the enclosure at Free field condition at 75% load as per CPCB-2 Norms.

SECTION - V AMF Panel

1.0 AMF Panel (inclusive of Control & Monitoring)

The AMF panel shall be PLC based, cubicle, floor mounting type with hinged type doors suitable for 415 Volt 50 Hz AC supply.

- i. The normal power supply shall be constantly monitored by a mains voltage monitor. When the mains voltage fail or drops below 80%, D.G. set should start.
- ii. System shall permit 3 attempts for starting the DG set: failing which the annunciation circuit shall be activated for alarm.
- iii. If the engine starts during 3 attempts & the engine reaches its operating speed and the alternator its operating voltage, the cranking circuits shall be isolated, and the load shall be transferred to the DG set.
- iv. Upon return of the normal supply voltage of 90% (adjustable & selectable) of the rated voltage for a minute, the load shall be transferred to the normal source. However, the DG set shall continue running for 10 minutes and then stop.
- v. If the DG set fails to start and reach its operating speed in 25 seconds in three attempts the DG set

- shall automatically be disconnected and locked in isolated position.
- vi. A clock / time switch shall be provided for automatic run of lube oil primer pump of the Engine for a specified period of time.
- vii. The AMF system shall include a battery charger for trickle / boost charging of AMF panel battery and DG set battery during DG set idling period. The charger shall be of approved capacity to cater to the battery requirements.
- ix AMF panel should be suitable to accommodate 3.5 core 70 sq.mm Al. armoured cable as incomer, 3.5 core 70 sq.mm Al. armoured cable from DG Set to AMF panel and 3.5 core 70 sq.mm Al armoured cable as common output from AMF Panel to Distribution Panel.

2.0 **Construction**:

- 2.01 All dimensions in mm.
- 2.02 Degree of Protection IP54.
- 2.03 Danger Notice Board shall be provided.
- 2.04 AMF Panel shall have following sections. Control & Monitoring Section.
 - i) Change over & power section.
- 2.05 Main Switch Board frame : 2 mm thick CRCA sheet.
- 2.06 Base Frame : 75 x 40 x 5 mm (Base frame should be

independent

Main Panel)

2.07 Frame for MCCB, MCBs : **2 mm thick CRCA sheet**

Protection relays, Contactors, instruments etc.

- 2.08 Partitions(internal/external) : 2 mm thick CRCA sheet
- 2.09 Fixing bracket for MCCB, Protection : Relays, Contactors, Rectifiers & other

Control & Monitoring compartments 2

mm thick CRCA sheet

2.10 Doors : Hinged type door made of 2 mm

thick CRCA sheet

2.11 Earthing Terminals (interconnected : **2 Nos.**

with 25 x 3 mm Copper strip)

2.12 Gland Plate : 3 mm thick CRCA sheet

2.13 Rating of Busbar : 1.5 times of FLC 99.9% pure 100%

conductivity electrolytic Copper tinned

2.14 Riser Connections for MCCB & : ------ do ------

Change over MCCB"s

2.15 Breaking Capacity : 55 KA

2.16 Control Circuit Voltage : 230 V 50 Hz AC

Control Circuit wiring : 2.5 sq. mm PVC FRLS Insulated

Copper wire

2.18 Control cable from DG Set to : 2.5 sq.mm. Copper AMF & PCC

conductor armoured (No. of cores depend on Control

Circuit/Mounting)

2.19 Panel manufacturer should have in house fabrication plant with CNC turret punching & NC bending machine. Manufacturer should have 7 tank pretreatment cleaning process & powder coating plant. If panel fabrication is to be outsourced by the contractor, the details of such panel manufacturers should be included in the offer.

TECHNICAL DATA SHEET & DOCUMENTATION (DOCUMENTS TO BE SUBMITTED WITH TECHNICAL BID)

1.0) DATA SHEET (Alternator)

Sr. No.	Details of Particulars	To be filled by Vendor
1.	Make:	
2.	Governing Specifications	
3.	Full load output in KVA	
4.	Ingress protection class of enclosure	
5.	Speed/ Frequency	
6.	No. of phases	
7.	Is neutral brought out?	
8.	Voltage between phase/ neutral	
9.	Regulation band of voltages	
10.	Short time overload at : 110 % load	
11.	Efficiency at 0.8 p.f. at various loads	
12.	Exciter type	
13.	Three phase sustained short circuit Current	
14.	AVR make, type & response time AVR shall be suitable for control from remote through push buttons.	
15.	Overall dimensions set (mm)	
16.	Weight of set overall (kg)	
17.	Head room needed for lifting/ Servicing	
18.	Other features of Alternator which are not covered above	

DATA SHEET - ENGINE

Sr.No.	DESCRIPTION	To be filled by Vendor
	GENERAL	
1.	Model no.	
2.	Manufacturer :	
	Cummins/ KOEL/ Caterpillar India/	
	Perkins/Volvo Penta	
3.	Number of cylinders	
4.	Bore/stroke	
5.	Displacement volume(cc)	
6.	Compression ratio/bmfp	
7.	Piston travel-continuous	
0	Speed	
8.	Continuous HP at max. Continuous rated speed.	
9.	Continuous max. Rated rpm	
10.	Normal working rpm	
-	FUEL SYSTEM	
11.	Fuel consumption at 0.8 power factor	
2)	with different load capacities	
a) b)		
c)		
12.	Fuel tank capacity	
121	LUBRICATION SYSTEM	
13.	Lube oil grade	
14.	Lube oil consumption	
15.	Lube oil filter – type and	
	replacement period	
16.	COOLING SYSTEM	
10.	Type of mechanism of cooling AIR INLET SYSTEM	
	Air filter: type and replacement	
	period	
17.	HP/WATTS absorbed by radiator	
	fan	
	EXHAUST SYSTEM	
18.	Exhaust gas temperature at	
	At stack at full load	
19.	Maximum permissible exhaust back	
	pressure at full load	
l	STARTING SYSTEM	

20.	BATTERY		
	a) Make		
	b) Voltage grade		
	c) AH capacity		
	d) Solenoid start switch make		
	e) Whether suitable for 6consecutive starts (yes/no)		
	Cabling (specify cable sq.mm, no. of cores) All control cables of 2.5 sq.mm. Copper armoured		

21.	Instrumentation system Make of level switch Make of pressure switch
	Make of mechanical Hour meter/ Digital hour Meter Make of pressure gauge, temperature gauge and other gauges.
22.	Noise level at 1 m, 75 db
23.	Governor Type, make and tolerance

Note:

- 1. Information/data marked as to be filled by Vendor shall be furnished by the bidder along with the offer. Failure to furnish data/information shall make the offer liable for rejection.
- 2. The bidder may supplement the data sheet to suit the particular design and model of engines offered and ensure that all relevant technical data and information are included in the datasheet.
- 3. Complete technical data on all auxiliary items such as governor, pumps, motors (if any), starting system, instrumentation and control system, etc. shall be included in the datasheet.
- 4. The materials details for the above items as applicable shall also be furnished.

Approved Makes

Sl.No.	ITEM DESCRIPTION	MAKE
1	Air circuit breaker	Schneider / L&T / ABB / GE
2	MCCB	Schneider / L&T / ABB / GE
3	Relays	AVK-SEGC / ABB / Telemechanique / L&T /Schneider
4	Power factor relay	Epcos / Ducati / Beluk / Enercon / Meher
5	Change over switch	HPL / Schneider / L&T / ABB
6	Power contactors	L&T / ABB / SCHNEIDER / TELEMECHANIQUE
7	Instrument transformers	Kappa / Kalpa / Instrans /Voltamp
8	Capacitor banks with series reactors with harmonic filters	Epcos / Ducati / Meher
9	LT panel fabrication including Bus duct	Power Control Equipments / Lotus Power gear / CPRI Approved
10	Meters	Conserv, L&T, AE. Elmeasure
11	Panel accessories / terminal Block	As per manufacturer specified make
12	MCB / MCB DB	Legrand / Schneider / Havells / L&T / ABB
13	ELCB / ELMCB / RCBO	Legrand / Schneider / Havells / L&T / ABB
14	LT Cable	Finolex/ Poly Cab / Havells /Gloster
15	End Termination Materials	Dowels / SMI / Wago
16	MS Powder coated Cable Tray	As per panel fabricator
17	PVC Conduits - FRLS	VIP / Avon / Precision / Universal
18	PVC Wires & Flexible Cables - FRLS	Anchor / Power Flex / Finolex / L&T / Havells
19	Modular switches and socket	Anchor Woods / MK / Legrand / L&T Oris
20	Industrial sockets	Legrand / L&T / ABB
21	Light fixtures - working area	Philips / Wipro / Thorn / GE
22	Light fixtures – decorative	Philips / Wipro / Thorn / GE
23	Street light pole	Klite / Shubham / Jindal
24	Glands - Single / Double Compression	Dowells
25	Aluminium / Copper Lugs	Dowells
26	Aviation Light	Bajaj / eq.
27	Surge Arrestors	L&T / ABB / OBO Betterman
28	DG Set	Cummins/ KOEL or equivalent as approved by EIC.

Annexure - C

Modification's in Clause 12 of GCC for Construction Works

The following modifications are made in the GCC for Construction Works.

The following modifications are made in Existing Provision	Modified Provision
Clause 12	Clause 12
Deviations/Variations Extent and Pricing	Deviations/Variations Extent and Pricing
The Engineer-in-Charge shall have power (i)	
to make alteration in, omissions from,	
additions to, or substitutions for the	
original specifications, drawings, designs	
and instructions that may appear to him to	
be necessary or advisable during the progress of the work, and (ii) to omit a part of the	No Change
works in case of non-availability of a	S
portion of the site or for any other reasons	
and the contractor shall be bound to carry	
out the works in accordance with any	
instructions given to him in writing signed	
by the Engineer-in-Charge and such	
alterations, omissions, additions or	
substitutions shall form part of the	
contract as if originally provided therein and any altered, additional or substituted	
work which the contractor may be directed	
to do in the manner specified above as part	
of the works, shall be carried out by the	
contractor on the same conditions in all	
respects including price on which he	
agreed to do the main work except as	
hereafter provided.	
12.1 The time for completion of the works	
shall, in the event of any deviations	
resulting in additional cost over the	
tendered value sum being ordered, be	
extended, if requested by the contractor,	No Change
as follows:	No Change
(i) In the proportion which the additional cost of the altered,	
additional or substituted work,	
bears to the original tendered value	
plus	
(ii) 25% of the time calculated in (i) above	
or such further additional time as may	
be considered reasonable by the	
Engineer-in-Charge.	

12.2 Deviation, Extra Items and Pricing

In the case of extra item(s) (items that are completely new, and are in addition to the items contained in the contract), the contractor may within fifteen days of receipt of order or occurrence of the item(s) submit market rate claim rates, supported by proper analysis which shall include invoices, vouchers etc. Manufacturer's specification for the work failing which the rate approved later by the Engineer- in- Charge shall be binding and the Engineer-in- Charge shall within prescribed time limit of the receipt of the claims supported by analysis, after giving consideration to the analysis of the rates submitted by the contractor, determine the rates on the basis of the market rates and the contractor shall be paid in accordance with the rates so determined, failing which it will be deemed to have been approved.

In the case of substituted items (items that are taken up with partial substitution or in lieu of items of work in the contract), the rate for the agreement item (to be substituted) and substituted item shall also be determined in the manner as mentioned in the following para.

- a) If the market rate for the substituted item so determined is more than the market rate of the agreement item (to be substituted), the rate payable to the contractor for the substituted item shall be the rate for the agreement item (to be substituted) so increased to the extent of the difference between the market rates of substituted item and the agreement item (to be substituted).
- b) If the market rate for the substituted item so determined is less than the market rate of the agreement item (to be substituted), the rate payable to the contractor for the substituted item shall be the rate for the agreement item (to be substituted) so decreased to the extent of the difference between the market rates of substituted item and the agreement item (to be substituted).

12.2 Deviation, Extra Items and Pricing

In the case of extra item(s) (items which are not available in the contract), the contractor may within fifteen days of the receipt of order or occurrence of the item(s), submit claim for market rate(s), supported proper analysis of rate with manufacturer's specification for the work, invoices, vouchers, etc. (as applicable), failing which the rate(s) approved later by the Engineer-in-Charge shall be final and binding. Where the contractor submits claim for market rate(s) in the manner prescribed above, the Engineer-in-Charge shall, within 45 days of the receipt of the claims, after giving consideration to the analysis of rates and submitted documents bv contractor, determine the rates on the basis of the market rates and the contractor shall be paid in accordance with the rates so determined.

The rate(s) of extra items so determined by the Engineer-in-Charge shall be final and binding on the contractor, and shall not be arbitrable.

Deleted

Deleted

Deviation, deviated Quantities, Pricing

In the case of contract items, substituted items, contract cum substituted items, which exceed the limits laid down in schedule F, the contractor may within fifteen days of receipt of order or occurrence of the excess, claim revision of the rates, supported by proper analysis for the work in excess of the abovementioned limits,......

and the contractor shall be paid in accordance with the rates so determined.

The prescribed time limit for finalizing rates for Extra Item(s), Substitute Item(s) and Deviated Quantities of contract items is within 45 days after submission of proposal by the contractor without observation of the Engineer-in-Charge.

12.3 The provisions of the preceding paragraph shall also apply to the decrease in the rates of items for the work in excess of the limits laid down in Schedule F, and the Engineer-in-Charge shall after giving notice to the contractor within one month of occurrence of the excess and after taking into consideration any reply received from him within fifteen days of the receipt of the

notice, revise the rates for the work in question within one month of the expiry of the said period of fifteen days having regard to the market rates.

12.4 For the purpose of operation of Schedule "F", the following works shall be treated as works relating to foundation unless & otherwise defined in the contract:

- (i) For Buildings: All works up to 1.2 meters above ground level or up to floor 1 level whichever is lower.
- (ii) For abutments, piers and well staining: All works up to 1.2 m above the bed level.
- (iii) For retaining walls, wing walls, compound walls, chimneys, overhead reservoirs/ tanks and other elevated structures: All works up to 1.2 meters above the ground level.

Deviation, deviated quantities, Pricing

In the case of contract items which exceed the limit laid down in Schedule F, the contractor may within fifteen days of the receipt of order or occurrence of the excess, claim revision of the rates, supported with proper analysis of rate and invoices, vouchers, etc. (as applicable), for the quantity in excess of the abovementioned limit. The Engineer-in-Charge shall within 45 days of receipt of the claims, after giving consideration to the analysis of rates and

other documents submitted by the contractor, determine the rates on the basis of the market rates and the contractor shall be paid in accordance with the rates so determined.

The rate(s) so determined by the Engineer-in-Charge shall be final and binding on the contractor, and shall not be arbitrable.

12.3 In the case of contract items which exceed the limit laid down in Schedule F, the Engineer-in-Charge shall after giving notice to the contractor within 30 days of submission of that bill by the contractor which contains such item(s), and after taking into consideration any reply received from the contractor within 15 days of the issue of such notice, reduce the

rate for quantity in excess of the abovementioned limit on the basis of market rates, within 30 days of the expiry of the said period of 15 days, and the contractor shall be paid in accordance with the rates so determined.

The rate(s) so determined by the Engineerin- Charge shall be final and binding on the contractor, and shall not be arbitrable.

Deleted

- (iv) For reservoirs/tanks (other than overhead reservoirs/tanks): All works up to 1.2 meters above the ground level.
- (v) For basement: All works up to 1.2 m above ground level or up to floor 1 level whichever is lower.
- (vi) For Roads, all items of excavation and filling including treatment of sub base.
- 12.5 Any operation incidental to or necessarily has to be in contemplation of tenderer while quoting tender, or necessary for proper execution of the item included in the Schedule of quantities or in the schedule of rates mentioned above, whether or not, specifically indicated in the description of the item and the relevant specifications, shall be deemed to be included in the rates quoted by the tenderer or the rate given in the said schedule of rates, as the case may be. Nothing extra shall be admissible for such operations.

Deleted

12.5 The cost of any operation necessarily in contemplation of tenderer while quoting tender or necessary or incidental to proper execution of an item of work included in the Schedule of Quantities or in the Schedule of Rates mentioned in Schedule F, whether or not specifically indicated in the description of the item and the relevant specifications, shall be deemed to be included in the rates quoted by the tenderer or the rate given in the said Schedule of Rates, as the case may be. Nothing extra shall be admissible for such operations.